



California Regional Water Quality Control Board

San Diego Region



Matthew Rodriguez
Acting Secretary for
Environmental Protection

Over 50 Years Serving San Diego, Orange, and Riverside Counties
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA

Edmund G. Brown, Jr.
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353
(858) 467-2952 • Fax (858) 571-6972
[http:// www.waterboards.ca.gov/sandiego](http://www.waterboards.ca.gov/sandiego)

February 10, 2012

In reply refer to:
271721:ccannova

Mr. Larry Brown
Warner Estates HOA
Warner Estates Mobile Estates
35109 Hwy 79
Warner Springs, CA 92086

Dear Mr. Brown:

**SUBJECT: REVIEW OF MONITORING REPORT FOR WARNER SPRINGS
MOBILE ESTATES**

The California Regional Water Quality Control Board, San Diego Region has reviewed the January-June 2011 and July-December 2011 semiannual monitoring reports, along with the January-December 2011 annual monitoring report submitted in accordance with Monitoring and Reporting Program No. 93-14.

The San Diego Water Board has identified the following violation of Order No. 93-14:

The 12 month average effluent limitation of Total Dissolved Solids (TDS), established at 750 milligrams per liter (mg/L) was exceeded on September 29, 2011 with a reported value of 770 mg/L.

Please take steps to implement follow-up actions necessary to ensure that the violation noted does not occur in the future. This violation subjects Warner Springs to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;¹ referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

The next monitoring report required to be submitted is the January-June 2012 semiannual annual monitoring report, which is due by July 30, 2012.

¹ Under authority of California Water Code section 13350.

Mr. Larry Brown

- 2 -

February 10, 2012

In the subject line of any response, please include the requested "In reply refer to" information located in the heading of this letter. For questions pertaining to the subject matter, please contact Ms. Catherine Cannova at (858) 627-3977 or via email at ccannova@waterboards.ca.gov.

Sincerely,

Brian D. Kelley

Brian D. Kelley, P.E.
Senior Water Resource Control Engineer
Cleanup and Land Discharge Branch

Regulatory Measure ID: 383071
Violation ID: 918755